
CITY OF SOMERSET SIDEWALK SPECIFICATIONS

NEW CONSTRUCTION:

- 1) The site shall be prepared for stable conditions with a minimum of 2" of 610 stone.**
- 2) All concrete shall be Class "A", with a maximum slump of 4"**
- 3) All concrete shall be a minimum of 4" thick by 54" wide.**
- 4) No reinforcement shall be required**
- 5) All concrete shall have fiber in concrete for additional strength.**

REPLACEMENT CONSTRUCTION:

- 1) All existing concrete shall be removed and disposed of at City's instruction.**
- 2) The site shall be prepared for stable conditions with a minimum of 2" of 610 stone.**
- 3) All concrete shall be Class "A", with a maximum slump of 4".**
- 4) No reinforcement shall be required.**
- 5) All concrete shall have fiber in concrete for addition strength.**
- 6) Sidewalk width shall be the same as previous unless specified**

CITY OFFICIAL BID SHEET

NEW CONSTRUCTION		REPALCEMENT CONSTRUCTION SIDEWALK		
#	SIDEWALK LENGTH	#	LENGTH	PRICE PER FOOT
1)	1' to 10'	1)	1' to 10'	
2)	11' to 20'	2)	11' to 20'	
3)	21' to 30'	3)	21' to 30'	
4)	31' to 40'	4)	31' to 40'	
5)	41' to 50'	5)	41' to 50'	
6)	51' to 60'	6)	51' to 60'	
7)	61' to 70'	7)	61' to 70'	
1)	71' to 80'	1)	71' to 80'	
2)	81' to 90'	2)	81' to 90'	
3)	91' to 100'	3)	91' to 100'	

By signing this document I certify that I have read and understand the attached specification for sidewalk construction and these are my prices.

OFFICIAL SIGNATURE _____

DATE _____