

INVITATION TO BID

The City of Somerset will be accepting sealed bids for the construction of new and replacement sidewalks to be performed at various times and locations in the City of Somerset.

All Bids shall be for sidewalk preparation, forming, and labor to pour the lengths as shown on the City Official Bid sheet and to the specifications for the City of Somerset sidewalks.

All bids shall be on the City Official Bid sheet and in effect from July 1, 2023 thru June 30, 2024. Official Bid sheet and specifications may be obtained at the Somerset Energy Center located at 306 E. Mt. Vernon Street.

Bids must be received by 10:00am on May 25, 2023 and should be addressed as follows:

Attn: Sidewalk Bid
City of Somerset
306 E. Mt. Vernon St.
Somerset, KY 42501

For more information about the sidewalk specifications contact David Hargis, Street Superintendent, at 606-679-1106. The City of Somerset reserves the right to reject any or all bids.

CITY OFFICIAL BID SHEET

NEW CONSTRUCTION			REPALCEMENT CONSTRUCTION SIDEWALK		
	SIDEWALK LENGTH	PRICE PER FOOT		LENGTH	PRICE PER FOOT
1)	1' to 10'		1)	1' to 10'	
2)	11' to 20'		2)	11' to 20'	
3)	21' to 30'		3)	21' to 30'	
4)	31' to 40'		4)	31' to 40'	
5)	41' to 50'		5)	41' to 50'	
6)	51' to 60'		6)	51' to 60'	
7)	61' to 70'		7)	61' to 70'	
1)	71' to 80'		1)	71' to 80'	
2)	81' to 90'		2)	81' to 90'	
3)	91' to 100'		3)	91' to 100'	

By signing this document I certify that I have read and understand the attached specification for sidewalk construction and these are my prices.

OFFICIAL SIGNATURE _____

DATE _____

CITY OF SOMERSET SIDEWALK SPECIFICATIONS

NEW CONSTRUCTION:

- 1) The site shall be prepared for stable conditions with a minimum of 2" of 610 stone.**
- 2) All concrete shall be Class "A", with a maximum slump of 4"**
- 3) All concrete shall be a minimum of 4" thick by 54" wide.**
- 4) No reinforcement shall be required**
- 5) All concrete shall have fiber in concrete for additional strength.**

REPLACEMENT CONSTRUCTION:

- 1) All existing concrete shall be removed and disposed of at City's instruction.**
- 2) The site shall be prepared for stable conditions with a minimum of 2" of 610 stone.**
- 3) All concrete shall be Class "A", with a maximum slump of 4".**
- 4) No reinforcement shall be required.**
- 5) All concrete shall have fiber in concrete for addition strength.**
- 6) Sidewalk width shall be the same as previous unless specified**